



**INDIANA UNIVERSITY**  
UNIVERSITY ARCHITECT'S OFFICE

**ADDENDUM # 2**

TO: bidders

FROM: Somsri Bond, RA, LEEDap  
Assistant Architect for Research, University Architect's Office

SUBJECT: 20180123 - EA802 - Whitewater Hall - Rms 221,223,225-Interior Finishes & Technology Upgrade  
Indiana University East Campus

DATE: Monday, September 17, 2018

---

This Addendum is issued in accordance with the provisions of the General Conditions for Indiana University Projects and becomes a part of the Contract Documents as provided therein. The requirements of the original Bid Documents remain in effect except as modified below.

Acknowledge receipt of this Addendum in the space provided on the Bid Proposal Failure to do so may subject the Bidder to disqualification.

Questions/Answers:

Questions:

- How deep are the wall cabinets for alternate 1 Lab 221 new casework? (DWG A2).
- Are we to do demo & re-installation of existing casework or just reinstallation? We recommend doing the demo if we will be re-installing.
- What are the sink sizes on Lab 221 new casework? (A2).
- What is a 'swivel sink strainer adapter with gasket (A1/construction note 2)?

Answers:

1. Alternate 1 wall cabinets, 1' deep or whatever manufacture standard is.
2. Student desks, to remove and put back after the flooring is completed. New casework, to remove/demo and install new casework. Casework vender will work with plumber under General contractor supervision. General contractor needs to answer the question whether casework vender to do demo work or not. I do agree that should be the same casework vender, so they will see the existing conditions and make the new casework fits.
3. Sinks size is on A2, if you do not have exact dimensions sizes, please submit for review.
4. We would like to have a heavy duty stainless steel basket strainer w/ tail piece and locknut that will fit over existing glass drain p-trap. If you have other typical compliance drain accessory standard for your epoxy resin sink, please provide for review...